

Agenda Item
No.

D-2

DATE SUBMITTED 12/27/21

SUBMITTED BY Public Services

DATE ACTION REQUIRED 01/05/22

COUNCIL ACTION ()
PUBLIC HEARING ()
REQUIRED
RESOLUTION ()
ORDINANCE 1ST READING ()
ORDINANCE 2ND READING ()
CITY CLERK'S INITIALS *(em)*

IMPERIAL CITY COUNCIL AGENDA ITEM

SUBJECT: DISCUSSION/ACTION: Emergency Booster Pump Station I. End Emergency declared by Resolution 2021-51	
DEPARTMENT INVOLVED: Public Services - WTP	
BACKGROUND/SUMMARY: A Variable Frequency Drive (VFD) failed at a critical Booster Pump Station at the Water Treatment Plant. VFD has been installed by Tess Electric and in operation since Mid-December.	
FISCAL IMPACT: \$32,977.00 Tess Electric	FINANCE INITIALS <u><i>HS</i></u>
STAFF RECOMMENDATION: Approve to End Emergency	DEPT. INITIALS <u><i>RS</i></u>
MANAGER'S RECOMMENDATION: <i>approve resolution ending emergency</i>	CITY MANAGER'S INITIALS <u><i>STW</i></u>
MOTION:	
SECONDED: AYES: NAYES: ABSENT:	APPROVED () REJECTED () DISAPPROVED () DEFERRED () REFERRED TO:

RESOLUTION NO. 2022-02

**RESOLUTION TERMINATING THE EMERGENCY FOR BOOSTER PUMP STATION
AT THE CITY OF IMPERIAL WATER TREATMENT PLANT**

WHEREAS, the City of Imperial (“City”) operates a water treatment plant and pumping facility (“Facility”) which consists of approximately sixty-three (63) miles of distribution piping; and

WHEREAS, the Imperial City Council declared an emergency by way of Resolution No. 2021-51 on August 4, 2021, in response to needed repairs to the booster pump station at the City of Imperial Water Treatment Plant; and

WHEREAS, the repairs to the booster pump station have since been completed.

NOW, THEREFORE, BE IT RESOLVED the emergency declared by resolution no. 2021-51 has been resolved and is now terminated.

APPROVED, PASSED, AND ADOPTED, at the regular meeting of the City Council this 5th day of January, 2022.

Geoff Dale, Mayor

ATTEST:

City Clerk