Agenda Item No. E-2

DATE SUBMITTED	11/29/2022	COUNCIL ACTION	( )
		PUBLIC HEARING REQUIRED	( )
SUBMITTED BY	Public Services	RESOLUTION	( )
		ORDINANCE 1ST READING	( )
DATE ACTION REQUIRED	12/07/2022	ORDINANCE 2ND READING	( )
		CITY CLERK'S INITIALS	( )

IMPERIAL CITY COUNCIL
AGENDA ITEM

SUBJECT: Continue Emergency Lift Stations

DISCUSSION/ACTION: Declare Emergency at Hwy 86 & Aten Rd.

1. Continue Emergency Action of Resolution NO. 2022-60

DEPARTMENT INVOLVED: Public Services – Waste Water

BACKGROUND/SUMMARY:

After replacing suction lines at three lift stations back in mid- June, Public Services inspected other pump & lift stations and found four other stations needing suction lines removed and replaced. Bracing and supports for these suctions line have also failed and will be replaced, as well. This is critical and considered an emergency repair to continuing to provide sewer collection in the areas of: Sandalwood Glen, Sky Ranch, Cross & Colonia Pump/Lift Stations. If lines continue to fail, these lift stations will not be able to function; each one currently has a failed line and are running at 50%.

Public Services is continuing to work with A&R Construction to rectify issues.

FISCAL IMPACT: TBD	FINANCE INITIALS
STAFF RECOMMENDATION: Council continues approval of emergency action	DEPT. INITIALS
MANAGER'S RECOMMENDATION: approve	CITY MANAGER's INITIALS

MOTION:

SECONDED:
AYES:
NAYES:
ABSENT:

APPROVED ( ) REJECTED ( )
DISAPPROVED ( ) DEFERRED ( )

REFERRED TO: